

Reut1An1 T79CLW161FR047 TMS
6/6/2022 4:21:00 PM
\\p81.ad.dot.state.mn.us:cddp\Documents\Projects\DM_R05\Non_Project\FrwOps\Detail\Drawings\CAB_LOOP_MISC\cab_loop_misc.dtl.dwg

NOTE:
EACH INSTALL DMS ITEM SHALL INCLUDE THE
INSTALLATION OF A 15' ONE PIECE GROUND
ROD AND THE INSTALLATION OF THE 7/16"
GROUNDING BRAID STRAPPED TO THE POWER
CONDUIT OR SIGN POST AS INDICATED (INCIDENTAL)

THE DMS GROUNDING BRAID WILL BE CONTINUOUS
FROM THE DMS GROUND LUG, THROUGH THE GROUND
ROD EXOTHERMICAL WELD, TO THE INTERNAL SIGN
POST GROUND LUG WHEN APPLICABLE

STRAP GROUNDING BRAID TO POST OR CONDUIT
AWAY FROM VIEW OF TRAFFIC.

DMS GROUNDING BRAID IS CONSTRUCTED OF
32 STRANDS OF 17 GAUGE TINNED COPPER WIRE, 7/16"
DIAMETER, BRAIDED SMOOTH TWIST,
65,500 CIRCULAR MILLS,
NET WEIGHT 215 LBS. PER 1000 FT.

JUNCTION BOXES MAY BE NECESSARY DEPENDING
ON CONDUIT CONFIGURATIONS. SEE PLAN NOTES.

