



FD. PT. H5T

LIGHTING STANDARDS AND BASES					
NO.	STATION	LT.	RT.	LOCATION	TYPE
1	INPLACE			T.H. 100 N.B.	68-40
2	INPLACE			T.H. 100 N.B.	12-40
3	INPLACE			T.H. 100 N.B.	12-40
4	INPLACE			T.H. 100 N.B.	12-40
5	INPLACE			T.H. 100 N.B.	12-40
6	INPLACE			T.H. 100 N.B.	12-40
7	INPLACE			T.H. 100 S.B.	12-40
8	INPLACE			T.H. 100 S.B.	12-40
9	INPLACE			T.H. 100 S.B.	12-40
10	INPLACE			T.H. 100 S.B.	12-40
11	INPLACE			T.H. 100 S.B.	12-40
12	INPLACE			T.H. 100 S.B.	68-40

FD. PT. H5T

LIGHTING STANDARDS AND BASES					
NO.	STATION	LT.	RT.	LOCATION	TYPE
13	166+20			T.H. 100 N.B.	12-40
14	41+85			S.E. RAMP	68-40
15	44+00			S.E. RAMP	68-40
16	46+15			S.E. RAMP	68-40
17	48+20			S.E. RAMP	68-40
18	168+58			T.H. 100 N.B.	12-40
19	170+98			T.H. 100 N.B.	12-40
20	173+38			T.H. 100 N.B.	12-40
21	175+30			T.H. 100 N.B.	12-40
22	175+15			T.H. 100 S.B.	12-40
23	172+85			T.H. 100 S.B.	12-40
24	170+60			T.H. 100 S.B.	12-40
25	168+30			T.H. 100 S.B.	12-40
26					
31	166+05			T.H. 100 S.B.	9D-40
27	39+50			S.W. RAMP	9-40
28	37+10			S.W. RAMP	68-40
29	34+80			S.W. RAMP	68-40
30	32+60			S.W. RAMP	9-40

LEGEND

- PAD MOUNTED SOURCE OF POWER, 240/480 VOLT
- INPLACE PAD MOUNTED SOURCE OF POWER, 240/480 VOLT
- ☼ INPLACE LIGHTING UNIT
- ☼ 250 WATT HIGH PRESSURE SODIUM LIGHTING UNIT
- ☼ 250 WATT HIGH PRESSURE SODIUM UNDERPASS LIGHTING FIXTURE
- 3" NON METALLIC CONDUIT UNLESS OTHERWISE NOTED
- ARMORED CABLE 3 CONDUCTOR NO. 4
- INPLACE ARMORED CABLE 3 CONDUCTOR NO. 4
- ⊥ GROUND ROD (25 OHMS OR LESS)
- INPLACE HANDHOLE
- HANDHOLE

